

### Programming Display

### Quick Start

STEPS	DISPLAY	ACTION		
<b>Main Display</b> Press   HOLD		<b>1st. Step</b> Press and Hold Both	SE-1 Default Set to	
<b>Low Level Value</b> Press 1x	 Low Value - 4mA = 0	<b>2nd. Step</b> Default Preset = 000.0 No need to change Press.	 4mA Empty	
Press 2 sec		<b>4th Step</b> In this screen press and hold  for 2 sec		
<b>High Level Value</b> Enter High Level Value	 Enter Max Tank Value	<b>5th Step</b> Move cursor Change number to desired value (Note: This value is your max tank level) Inches   Gallons   Liters		SE-2 Set High Liquid Level Value Value = Max Fill Height
Press 2 sec to SAVE		<b>6th Step</b> Press 2 sec to SAVE		Inches   Gal 
<b>Return to Main Display</b> Press   HOLD		<b>7th Step</b> Press & Hold Return to Main Display		
	 Current Level Value	<b>Finished</b> Current Tank Level		